

Environmental Test Laboratory

Alphatech Ltd, Green House, Homefield Road Ind Est, Haverhill, Suffolk. CB9 8QP
Tel: 01440 714709 Web: www.alphatech.co.uk email: info@alphatech.co.uk
Fax: 01440 714706

Certificate of Test Conformance Number: 103126 Issue 1

Customer Name & Address: East Electrical Services Ltd
23 Brookside Industrial Estate
Sawtry
Cambridgeshire
PE28 5SB

Customer Order Number: None – Ref Dave Roche email 11th July 2017

Test Item(s) Receipt Date: 11th July 2017

Test Item(s) Description: Electrical Outlet Cover

Test Item(s) Part Number(s): SKPT-1

Test Item(s) Serial Number(s): None

Test Item(s) Quantity: 1

Reference Standard(s): BS EN 60529: 1992 + A2: 2013:
Degrees of Protection Provided by Enclosures

Applied Test(s): IPx1

Test Date(s): 12th July 2017

Test Results: The detailed test was performed in accordance with the defined environmental test standard.

No water ingress was observed; hence the test item conformed to the requirements of the IPx1 rating.

Author:



Paul Lee
Senior Environmental Test Engineer

Approval:



Steve Drane
Service Manager

Issue Date:

13th July 2017

The results detailed herein relate only to the test item(s) submitted for testing